



20 Duke St, Suite 109  
Bedford, NS B4A 2Z5  
Web: www.toalltech.com

Ph: 902.835.3727  
Fax: 902.835.5266  
Email: email@toalltech.com

## Final Clearance Air Monitoring Report

**Client:** Gary Mannette  
Halifax Regional School Board  
33 Spectacle Lake Drive  
Dartmouth, Nova Scotia  
B3B 1X7

**Project:** 24945  
**Location:** Shannon Park Elementary School  
**Shift:** N/A  
**Date:** February 17<sup>th</sup>, 2019  
**Report #:** 06

### Summary:

Air monitoring was performed within Room 14 (4 enclosures), Room 18 and Room 22 after penetrations were made in asbestos containing plaster to facilitate ceiling access in the area. Results of the air monitoring show that the samples were below all applicable guidelines and the area is safe for occupancy.

### 1. Details to be noted:

On February 17<sup>th</sup>, 2019, Tyler Briand of ALL-TECH Environmental Services Limited collected six (6) final clearance air samples inside the enclosures (<270 m<sup>3</sup> each) constructed within various areas of the Shannon Park Elementary School located at 75 Iroquois Drive in Dartmouth, Nova Scotia. The inspection that verified the enclosures to be ready for final clearance air testing was performed by Belfor. The final clearance air samples were collected to demonstrate that airborne fibers were below 0.01 f/cc at the time of testing.

During final air clearance sampling, aggressive techniques (forced air) were utilized to disturb any loose fibers from all surfaces within the work enclosure to ensure a representative sample of all potential fibers within the area were collected. Please see below for results.

### 2. Sample Protocol:

During samples collection, the NIOSH 7400 Method was followed. The samples were collected on 3-piece, 25mm cellulose-ester sampling cassettes with a pore size of 0.8µm. The air-sampling pumps used to collect the air samples were Gastec® Medium Volume Air Sampling Pumps. Prior to air sampling, the pumps were calibrated using a TSI® Primary Calibrator Model #4146, Serial No. 414608446012 (NIST Traceable).

### 3. Air Monitoring Results:

Sample Number	Date of Collection	Time of Collection	Sample Duration (Minutes)	Flow Rate (LPM)	Sample Volume (Litres)	Sample Location / Description	Results (F/cc)
28-104	February 17 <sup>th</sup> , 2019	10:00 am	80	15.0	1200	Inside Enclosure #1 – Classroom 14 (<270 m <sup>3</sup> ) / <b>Final Clearance Air Sample</b>	<b>&lt;0.01</b>
28-105	February 17 <sup>th</sup> , 2019	10:00 am	80	15.0	1200	Inside Enclosure #2 – Classroom 14 (<270 m <sup>3</sup> ) / <b>Final Clearance Air Sample</b>	<b>&lt;0.01</b>
28-106	February 17 <sup>th</sup> , 2019	10:00 am	80	15.0	1200	Inside Enclosure #3 – Classroom 14 (<270 m <sup>3</sup> ) / <b>Final Clearance Air Sample</b>	<b>&lt;0.01</b>
28-107	February 17 <sup>th</sup> , 2019	10:00 am	80	15.0	1200	Inside Enclosure #4 – Classroom 14 (<270 m <sup>3</sup> ) / <b>Final Clearance Air Sample</b>	<b>&lt;0.01</b>
28-108	February 17 <sup>th</sup> , 2019	10:05 am	80	15.0	1200	Inside Enclosure – Classroom 18 (<270 m <sup>3</sup> ) / <b>Final Clearance Air Sample</b>	<b>&lt;0.01</b>
28-109	February 17 <sup>th</sup> , 2019	10:10 am	80	15.0	1200	Inside Enclosure – Classroom 22 (<270 m <sup>3</sup> ) / <b>Final Clearance Air Sample</b>	<b>&lt;0.01</b>

Results of air testing indicate airborne levels of fibres to be below 0.01 F/cc, or Fibres per Cubic Centimetre as set by the Province of Nova Scotia's Department of Labour and Advanced Education, Code of Practice "A Guide to Removal of Friable Asbestos Containing Material", Section 8, Sub-section 5 (Nov. 21, 2013).

The above noted samples were analyzed using the **NIOSH 7400 Method, (Asbestos and Other Fibres by PCM), following "A" Counting Rules**. NIOSH states in section titled APPLICABILITY that "This method gives an index of airborne fibres. It is primarily used for estimating asbestos concentrations, though PCM does not differentiate between asbestos and other fibres. This method will not detect fibres <0.25µm in diameter".

If you have any questions or comments regarding the above noted results, please feel free to contact our office at your convenience.

Thanks,



Tyler Briand  
Environmental Technician  
**ALL-TECH Environmental Services Ltd.**